

SAP Appendix Q Performance

| Exhaust terminal configuration | Specific fan power (W/l/s) | Heat recovery efficiency (%) | Energy Saving Trust best practice |
|---------------------------------------|---------------------------------------|---|--|
| Kitchen + 1 additional wet room | 0.85 | 85 | Yes |
| Kitchen + 2 additional wet rooms | 0.81 | 85 | Yes |
| Kitchen + 3 additional wet rooms | 0.88 | 84 | No |